



**MONTEREY BAY AIR RESOURCES DISTRICT**

24580 Silver Cloud Court, Monterey, CA 93940

(831) 647-9411, [www.mbard.org](http://www.mbard.org)

**VEEDER ROOT VAPOR POLISHER HC EMISSIONS TEST**

**Exhibit 12 of ARB E.O. VR 203-X or VR 204-X**

SOURCE INFORMATION			TEST COMPANY INFORMATION		
Facility (DBA)/Site Address:		Facility Representative/Title:	Test Company Name/Address		Test Company Representative
Print Name		Print Name	Print Name		Print Name
Street Address		Title	Street Address		Signature
City	Zip	Phone No.	City	Zip	Phone No.
District Test Witness:		Permit Number:	Date of Test:		ICC Cert. No:
			Time of Test		Phase II Manufacturer Cert No:

STEP 6.2 6.3	<b>CAL GAS DOCUMENTATION ATTACHED?</b> Yes No <b>HC ANALYZER ZERO CHECK READING:</b> _____ <b>HC ANALYZER CAL CHECK READING:</b> _____ <b>IS THE ZERO READING &lt; 1,000 ppm?</b> Yes No <b>IS THE CAL CHECK READING BETWEEN 8,000 and 10,000 ppm?</b> Yes No (IF NO: THE HC ANALYZER MUST BE RE-CALIBRATED.)
STEP 6.5 6.6	<b>3-WAY VALVE IN CORRECT POSITION (PER FIG. 1)?</b> Yes No <b>PMC VALVE MODE SET TO MANUAL OPEN?</b> Yes No
STEP 7.1	<b>START FLOW RATE:</b> _____ <b>END FLOW RATE:</b> _____
STEP 7.3	<b>HC READING AT 3 MIN:</b> _____ <b>HC READING AT 4 MIN:</b> _____ <b>HC READING AT 5 MIN:</b> _____ <b>HC READING AT 6 MIN:</b> _____ <b>IS THE HC CONC. &lt; 9,000 ppm FOR ALL READINGS?</b> Yes No (IF NO: THE VR POLISHER IS NOT IN COMPLIANCE WITH THE HC EMISSION REQUIREMENTS OF EXHIBIT 2.)
STEP 7.5	<b>3-WAY VALVE SET TO NORMAL OPEN POSITION?</b> Yes No <b>(UST Ullage to Vapor Polisher)</b> <b>RE-SET VAPOR VALVE TO AUTOMATIC MODE?</b> Yes No