

Average Torque must be 108 pound-inches or less to pass.

*Note: Every applicable field requires an entry.

24580 Silver Cloud Court, Monterey, CA 93940 (831) 647-9411, www.mbard.org

STATIC TORQUE OF ROTATABLE PHASE I ADAPTORS (TP 201.1B)

| ☐ Annual Testing ☐ Engineering Startup Evaluation | | | |
|--|--|--|--|
| SOURCE INFORMATION | | TEST COMPANY INFORMATION | |
| Facility (DBA)/Site Address: | Facility Representative/Title: | Company Name/Address | Company Representative |
| Print Name | Print Name | Print Name | Print Name |
| Print DBA (if applicable) | Title | Street Address | Signature |
| Street Address | Phase I System: Executive Order #: | City Zip | Phone No. |
| City Zip | Phone No. | Date of Test | ICC Cert. No. |
| District Test Witness: | ☐ P/O ☐ A/C Number: | | |
| Measurement units: (circle one): pound-inches pound-feet | | | |
| Vapor Adaptor 1 | Vapor Adaptor 2 | Vapor Adaptor 3 | Vapor Adaptor 4 |
| Make: | Make: | Make: | Make: |
| Model: | Model: | Model: | Model: |
| Product Grade: | Product Grade: | Product Grade: | Product Grade: |
| Able to Rotate 360 degrees ☐ Yes ☐ No | Able to Rotate 360 degrees ☐ Yes ☐ No | Able to Rotate 360 degrees ☐ Yes ☐ No | Able to Rotate 360 degrees ☐ Yes ☐ No |
| Torque 1: | Torque 1: | Torque 1: | Torque 1: |
| Torque 2: | Torque 2: | Torque 2: | Torque 2: |
| Torque 3: | Torque 3: | Torque 3: | Torque 3: |
| Average Torque: | Average Torque: | Average Torque: | Average Torque: |
| ☐ Pass ☐ Fail | ☐ Pass ☐ Fail | ☐ Pass ☐ Fail | ☐ Pass ☐ Fail |
| Product Adaptor 1 | Product Adaptor 2 | Product Adaptor 3 | Product Adaptor 4 |
| Make: | Make: | Make: | Make: |
| Model: | Model: | Model: | Model: |
| Product Grade: | Product Grade: | Product Grade: | Product Grade: |
| Able to Rotate 360 degrees ☐ Yes ☐ No | Able to Rotate 360 degrees Yes No | Able to Rotate 360 degrees ☐ Yes ☐ No | Able to Rotate 360 degrees ☐ Yes ☐ No |
| Torque 1: | Torque 1: | Torque 1: | Torque 1: |
| Torque 2: | Torque 2: | Torque 2: | Torque 2: |
| Torque 3: | Torque 3: | Torque 3: | Torque 3: |
| Average Torque: | Average Torque: | Average Torque: | Average Torque: |
| □ Pass □ Fail | ☐ Pass ☐ Fail | ☐ Pass ☐ Fail | □ Pass □ Fail |

adaptors tested_

adaptors failed _