





















Agenda Item No. 4

Exhibit A

List of Natural Gas Emergency Generators

Variance from the Permit to Operate requirement of Condition No. 3 which states, "except for test and exercise purposes, this equipment shall only be operated when the local utility power line service fails." The following pages include copies of permits 13274, 13275, 11745, 14996, 14997, 14998, and 14999.

Generator Number (PTO)	LOCATION	Rated	Maximum
		KW	Hours
GS-011 (13274)	Baskin Engineering Standby	206	96
GS-025 (13275)	Baskin Engineering	50	96
GS-040 (11745)	Engineering 2 Bldg.	150	96
GS-052 (14996)	Bio-Med Bldg. Emergency	150	96
GS-053 (14997)	Bio-Med Bldg. Standby	200	96
GS-054 (14998)	Bio-Med Bldg. Standby	200	96
GS-055 (14999)	Bio-Med Bldg. Standby	200	96