



MONTEREY BAY AIR RESOURCES DISTRICT

24580 Silver Cloud Court, Monterey, CA 93940

(831) 647-9411, www.mbard.org

DISPENSER INTEGRITY TEST

VR-201 and VR-202 Exhibit 14

Renewal Testing

Engineering Startup/Evaluation

| SOURCE INFORMATION | | | TEST COMPANY INFORMATION | | |
|------------------------|-----|----------------|--------------------------|-----|---------------------------------|
| Facility Name & DBA | | Contact Name | Company Name | | Tester Name |
| Street Address | | Title | Street Address | | Signature |
| City | Zip | Phone No. | City | Zip | Phone No. |
| District Test Witness: | | Permit Number: | Date of Test: | | ICC Cert. No: |
| | | | Time of Test | | Phase II Manufacturer Cert. No: |

| Dispenser # | Initial Vacuum Value | Final Vacuum Value (after 60 seconds) | Difference | Pass/Fail * | Pump Speed Change? |
|-------------|----------------------|---------------------------------------|------------|-------------|--|
| | | | | | <input type="checkbox"/> YES <input type="checkbox"/> NO |
| | | | | | <input type="checkbox"/> YES <input type="checkbox"/> NO |
| | | | | | <input type="checkbox"/> YES <input type="checkbox"/> NO |
| | | | | | <input type="checkbox"/> YES <input type="checkbox"/> NO |
| | | | | | <input type="checkbox"/> YES <input type="checkbox"/> NO |
| | | | | | <input type="checkbox"/> YES <input type="checkbox"/> NO |
| | | | | | <input type="checkbox"/> YES <input type="checkbox"/> NO |
| | | | | | <input type="checkbox"/> YES <input type="checkbox"/> NO |
| | | | | | <input type="checkbox"/> YES <input type="checkbox"/> NO |
| | | | | | <input type="checkbox"/> YES <input type="checkbox"/> NO |
| | | | | | <input type="checkbox"/> YES <input type="checkbox"/> NO |
| | | | | | <input type="checkbox"/> YES <input type="checkbox"/> NO |

* Dispenser Integrity Test fails when the vacuum reading falls more than 4.0 inH₂O in 60 seconds. Repair leaks as recommended in IOM Section 8. Retest until all leaks have been repaired.