

**ENGINEERING EVALUATION
AUTHORITY TO CONSTRUCT APPLICATION**

Company: City of Greenfield

Mailing Address: P O Box 127
Greenfield, CA 93927

Contact Person : Jamie Tugel
Cell: (831) 674-2635
Email : jtugel@ci.greenfield.ca.us

Project Location: 131 South El Camino Real
Greenfield, CA 93927

Authority to Construct: MOD-25-00025

Coordinates: Latitude: 36.315748 ° N
Longitude: 121.238794 ° W

SIC No.: 4952 (Sanitary Services – Sewage Systems)
NAICS No: 221320 (Sewage Systems)
SCC No: 20100102 (Fuel Combustion, Electric Generation, and Oil)

Engineer: Chathura Viswanath

Evaluation Date: November 2025

I. PROPOSAL DESCRIPTION

EMERGENCY DIESEL INTERNAL COMBUSTION ENGINE-GENERATOR SET:

The City of Greenfield has submitted a permit modification application to replace the existing engine listed under PTO 13442. This application also reflects the change of address from 105 South El Camino Real, Greenfield, CA listed on PTO 13442 to 131 South El Camino Real, Greenfield, CA. They propose to install an FPT Industrial S.p.A engine model F4GE9485A*J, Tier 3 engine, generator model Generac SD080. The diesel emergency internal combustion engine rated at 131 BHP @ 1800 RPM, will provide electric generation in the event of a power outage to the wastewater lift station site located at 131 South El Camino Real, Greenfield, CA. The proposed engine is located within 1000 feet of Greenfield High school.

II. APPLICABLE RULES

Rule 200: Permits Required
Rule 201: Sources Not Requiring Permits
Rule 207: Review of New and Modified Stationary Sources
Rule 218: Title V Operating Permits
Rule 221: Federal Prevention of Significant Deterioration
Rule 222: Federal Minor New Source Review
Rule 300: MBARD Fees

- Rule 400: Visible Emissions
- Rule 402: Nuisance
- Rule 403: Particulate Matter
- Rule 404: Sulfur Compounds & Nitrogen Oxides
- Rule 412: Sulfur Content of Fuels
- Rule 436: Title V: General Prohibitory Rule
- Rule 1000: Toxic Air Contaminants
- Air Toxic “Hots Spots” Information and Assessment Act
- 40 CFR Part 63, Subpart ZZZZ, NESHAP, National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines
- 40 CFR Part 60, Subpart IIII, NSPS, Stationary Compression Ignition Internal Combustion Engines.
- CA Health & Safety Code, Section 42301.6 – Public Notice.

III. PROCESS DESCRIPTION

Emergency Internal Combustion Engine-Generator Set:

Generac Generator Set, Model SD080, With A Rating Of 80 KW, Unit Powered By A 2024 Model Year FPT Industrial S.p.A Engine Model F4GE9485A*J, Rated At 131 BHP @ 1800 RPM, Certified Tier 3 Engine, EPA Family Name RFPXL06.7DGB Tier 3, Equipped With A Turbocharger And Aftercooler.

IV. DESIGN VIEW AND EMISSIONS CALCULATIONS

Table 1. Diesel Engine Emission Factors.

Pollutant Species	Emission Factor (g/kW-hr)	Emission Factor (g/Hp-hr)
NO _x ^{1,2}	3.65	2.72
VOC ^{1,2}	0.11	0.08
CO ¹	0.80	0.60
PM ¹	0.16	0.12
SO _x ³	-----	0.0050

Notes:

1. Diesel Engine Emission Factors except SO_x were gathered from the Generac Statement of Exhaust Emissions 2024 FPT Diesel Fueled Generator, Engine model F4GE9485A*J, for Engine family RFPXL06.7DGB.
2. The manufacturer provided NO_x + NMHC emission factor of 2.80 g/bhp-hr, which 3% (0.08 g/bhp-hr) was associated as VOC and 97% (2.72 g/bhp-hr) as NO_x, per MBARD correlation.
3. The SO_x emission factor was calculated assuming that certified diesel fuel was used and that all sulfur in the fuel is combusted into SO_x as SO₂. Based upon an ultra-low sulfur diesel concentration of 15 ppm the SO_x emission factor is as follows:

$$1.5E-5 \text{ lb/lb-diesel} * 7.05 \text{ lb.-diesel/gal-diesel} * 64 \text{ lb-SO}_2\text{/lb-mol} * \text{lb-mol S/32 lb-S} = 2.12E-4 \text{ lb-SO}_2\text{/gal-diesel}$$

$$\text{SO}_x \text{ Emission Factor (g/hp-hr)} = 2.12E-4 \text{ lb-SO}_2\text{/gal-diesel} * \text{Engine Fuel Consumption Rate (gal/hr)} * 1/\text{Engine Hp} * 454 \text{ g/lb}$$

$$= 2.12E-4 \text{ lb-SO}_2\text{/gal-diesel} * 6.84 \text{ gal/hr} * 1 / 131 \text{ Hp} * 454\text{g/lb} = 0.0050 \text{ g/bhp-hr}$$

Table 2. Emergency Diesel Engine Specifications.

EPA Family Name	RFPXL06.7DGB
Maximum Fuel Consumption Rate (gph) ²	6.84
Engine Horsepower (hp) ³	131
Exhaust Flowrate (cfm) ¹	790
Exhaust Temperature (°F) ¹	887
Exhaust Stack Height (ft.) ²	5.75
Exhaust Stack Diameter (in.) ²	3

Notes:

1. The exhaust flowrate and temperature, and fuel consumption referenced the Generac FPT Diesel Fueled Generator, Engine model F4GE9485A*J.
2. The exhaust diameter and exhaust height were provided by the applicant.
3. The engine power rating referenced the Generac Statement of Exhaust Emissions 2024 FPT Diesel Fueled Generator.

Table 3. Emergency Diesel Engine Potential To Emit (PTE) Emission Calculations

Pollutant	Operating Schedule (hr/day)	Power Rating (hp)	Emission Factor (g/hp-hr)	Daily Fuel Usage (gal/day)	PTE Emissions (lb/day)	Emission Factor (lb/gal)	PTE Emissions (tons/yr)
NO _x	24	131	2.72	164.16	18.85	0.1148	0.196
VOC	24	131	0.08	164.16	0.57	0.0035	0.006
CO	24	131	0.60	164.16	4.13	0.0252	0.043
PM	24	131	0.119	164.16	0.83	0.0051	0.009
PM ₁₀	24	131	0.115	164.16	0.79	0.0048	0.008
PM _{2.5}	24	131	0.112	164.16	0.77	0.0047	0.008
SO _x	24	131	0.0050	164.16	0.03	0.0002	0.0003
Total: NO _x + VOC + CO + PM + SO _x							0.254

Notes:

1. According to U.S. EPA Memo dated on 9/6/2005, 500 hours per year of max operation was used to calculate the potential annual emissions.
2. PM₁₀ and PM_{2.5} values are calculated from CEIDARS PM speciation profile. PM₁₀ is 96% and PM_{2.5} is 93.7% of PM.

V. RULE COMPLIANCE

The following MBARD rules apply to the operation as specified:

MBARD Rule 200 – Permits Required

The purpose of this Rule is to identify when MBARD permits are issued. The provisions of this Rule shall apply to any person who builds, erects, alters, or replaces any article, machine, equipment or other contrivance which may cause the issuance of air contaminants or the use of which may eliminate or reduce or control the issuance of air contaminants.

Pursuant to Section 3.1, no person shall build, erect, alter, or replace any article, machine, equipment or other contrivance which may cause the issuance of air contaminants or the use of which may eliminate or reduce or control the issuance of air contaminants unless the facility owner or operator has obtained a separate written Authority to Construct for each permit unit from the Air Pollution Control Officer. An Authority to Construct shall remain in effect until the Permit to Operate the equipment for which the

application was filed is granted or denied or the application is cancelled. Exceptions to MBARD Rule 200 are identified in MBARD Rule 201.

MBARD Rule 201 – Sources Not Requiring a Permit

MBARD Rule 201, Section 4.14 exempts engines with a power rating of less than 50 BHP from obtaining permits. The diesel engine in this application is rated at **131 BHP**. Therefore, this unit is subject to permitting requirements.

MBARD Rule 207 – Review of New or Modified Sources (as adopted on 4/20/2011)

This Rule provides for the review of new and modified stationary air pollution sources to meet requirements for the review of new and modified stationary sources (NSR) and for the Prevention of Significant Deterioration (PSD), under the provisions of the federal Clean Air Act; and requirements for NSR under the provisions of the California Clean Air Act. The intent of this Rule is to ensure that the most stringent requirements of these programs shall be applied.

This Rule shall apply to all new stationary sources and all modifications to existing stationary sources which, after construction or modification, emit or have the potential to emit any affected pollutants. A modification per Section 2.33.1 is defined as any physical change that would result in an actual or potential emissions increase.

Table 4a. Comparison of Potential to Emit of Existing Project to Potential to Emit of Proposed Project.

Application/PTO No. Equipment Description	Total Emission ² (tons/year)						
	NO _x	VOC	CO	SO _x	PM	PM ₁₀	PM _{2.5}
PTO 13442 Emg Eng-Gen Set	0.250	0.016	0.055	0.0002	0.007	0.007	0.007
MOD-25-00025 Emg Eng-Gen Set	0.196	0.006	0.043	0.0003	0.009	0.008	0.008
Difference	0.054	0.000	0.012	-0.0001	-0.002	-0.001	-0.001

1. SO_x emissions have been updated as calculated below:
 $2.12E-4 \text{ lb-SO}_2/\text{gal-diesel} * 4.20 \text{ gal/hr} * 1/95 \text{ Hp} * 454 \text{ g/lb} = 0.0042 \text{ g/bhp-hr}$
2. Per EPA guidance of 500 hours per year to calculate the max PTE in one year.

As demonstrated above in Table 4a, the new unit results in a potential emissions increase in SO_x. Thus, the proposed project is subject to the requirements of Rule 207.

This Rule shall apply to all new stationary sources and all modifications to existing stationary sources which, after construction or modification, emit or have the potential to emit any affected pollutants. Thus, the project is subject to the requirements of Rule 207.

Federal Best Available Control Technology (BACT) Analysis

Pursuant to Section 4.1.1, an applicant shall apply Best Available Control Technology (BACT) to a new stationary source or modification of an existing source, which has the potential to emit greater than or equal to any one of the affected pollutant levels listed in Table 4.1.1 or a modification of an existing stationary

source which has the potential to result in a new emissions increase, as defined in Section 2.37, occurring after October 20, 2010 for PM_{2.5} or after August 19, 1983 for PM₁₀ or after July 15, 1976 for any other affected pollutant.

Table 4b shows the emissions from the project, the facility-wide new emissions and the Federal BACT thresholds of Table 4.1.1.

Table 4b. Federal New Emission Increase – BACT Determination

Permit No. Equipment Description (Installation Date) ¹	NO _x (lb/day)	VOC (lb/day)	CO (lb/day)	SO _x (lb/day)	PM (lb/day)	PM ₁₀ (lb/day)	PM _{2.5} (lb/day)
MOD-25-00025 Emg. Diesel Engine (2025)	18.85	0.57	4.13	0.03	0.83	0.79	0.77
Total	18.85	0.57	4.13	0.03	0.83	0.79	0.77
Federal Threshold	150	150	550	150	150	82	54.79

Table 4b demonstrates that the facility does not exceed Federal BACT thresholds. Regardless, the Tier-3 engine meets current MBARD BACT standards for emergency engines rated $100 \leq \text{HP} < 175$ as outlined in MBARD’s *Clarification of Permit Requirements for Non-Agricultural Diesel Engines*, January 24, 2023, Table 1, summarized below in Table 5.

Table 5. BACT Guidelines for Stationary Emergency Engines At Non-Major Sources

Engine Rating/Size	PM	NO _x + NMHC	CO
$100 \leq \text{HP} < 175$	0.15 g/bhp-hr, or 0.20 g/kW-hr	3.0 g/bhp-hr, or 4.0 g/kW-hr	3.7 g/bhp-hr, or 5.0 g/kW-hr
MOD-25-00025 Emg IC Eng 131 HP	0.09 g/bhp-hr	2.80 g/bhp-hr	0.45 g/bhp-hr

California BACT Analysis

Pursuant to Section 5.2, BACT shall be required for any new or modified permit unit with a potential to emit 25 pounds per day or more of VOCs or NO_x.

Table 6. California BACT determination.

Pollutant	BACT threshold (lb/day)	Project emissions (lb/day)	BACT Applicability
NO _x	25	18.85	Does Not Trigger BACT
VOC	25	0.57	Does Not Trigger BACT

Table 6 demonstrates that the facility does not exceed the California BACT thresholds.

The Tier-3 engine meets current MBARD BACT standards for emergency engines, as referenced in the Federal BACT discussion above and in Table 5.

Federal & California Stationary Source Offsets Analysis

Pursuant to Rule 207 Section 1.3.3, emergency internal combustion engine emissions are not subject to offset thresholds and the emissions are not included in the facility’s net emission increase or accumulation.

In addition, Section 1.3.4 of MBARD Rule 207 states the following “the requirements to conduct Visibility, Soils and Vegetation Analysis, provide offsets, and conduct an Air Quality Increment Analysis of this Rule shall not apply to any Stationary Source that has emissions less than 10 tons/year of each individual criteria pollutants. As summarized in Table 9, the facility is below the 10 ton/year threshold for each criteria pollutant.

MBARD Rule 207 – Review of New or Modified Sources (as adopted on 2/15/2017)

Note that MBARD has not received approval for the 2/15/2017 version of Rule 207 and is implementing Rule 207 as adopted on 4/20/2011. For informational purposes only, the Rule applicability of Rule 207 as adopted on 2/15/2017 is summarized below.

The purpose of this Rule is to provide for the review of new and modified stationary air pollution sources to meet the New Source Review requirements under the provisions of the California Clean Air Act. This Rule provides mechanisms by which Authorities to Construct may be granted to such sources without interfering with the attainment or maintenance of California ambient air quality standards. Each project subject to New Source Review shall undergo a review under the federal requirements contained within Rule 220 and Rule 221, and a parallel review under the requirements of this Rule and the most stringent applicable provisions shall apply.

Rule 207 applies to all new stationary sources and all modifications to existing stationary sources, which after construction or modification, emit or have the potential to emit any affected pollutants. This project is subject to the requirements of this Rule.

Best Available Control Technology (BACT) requirements

Pursuant to Section 4.1.1, BACT shall be required for any new or modified permit unit with a potential to emit 25 pounds per day or more of VOCs or NO_x.

Table 7. Permit Unit BACT Determination

Pollutant	BACT threshold (lb/day)	Project emissions (lb/day)	Compliance
NO _x	25	18.85	Does Not Trigger BACT
VOC	25	0.57	Does Not Trigger BACT

As shown in Table 7, the project does not exceed the BACT thresholds of Section 4.1.1.

The Tier-3 engine meets current MBARD BACT standards for emergency engines rated $100 \leq \text{HP} < 175$, as outlined in MBARD’s *Clarification of Permit Requirements for Non-Agricultural Diesel Engines*, January 24, 2023, Table 1, summarized above in Table 5.

Pursuant to Section 4.1.2, BACT shall be required for a new or modified stationary source which has the potential to emit greater than or equal to any one of the affected pollutant levels listed in Table 4.1.1.

Table 8. Facility-Wide BACT Determination

Permit No.	NO _x (lb/day)	VOC (lb/day)	CO (lb/day)	SO _x (lb/day)	PM (lb/day)	PM ₁₀ (lb/day)	PM _{2.5} (lb/day)
MOD-25-00025 Emg Engine	18.85	0.57	4.13	0.03	0.83	0.79	0.77
Total	18.85	0.57	4.13	0.03	0.83	0.79	0.77
BACT Threshold	150	150	550	150	150	82	54.79

Table 8 shows the facility-wide emissions do not exceed the BACT thresholds of Section 4.1.2 for any criteria pollutant. Regardless, the Tier-3 engine meets current MBARD BACT standards for emergency engines rated $175 \leq \text{HP} < 750$ BHP, as referenced in BACT thresholds of Section 4.1.1 discussion and Table 5.

Stationary Source Offsets

Pursuant to Rule 207 Section 1.3.3, emergency internal combustion engine emissions are not subject to offset thresholds and the emissions are not included in the facility’s net emission increase or accumulation. In addition, Section 1.3.4 of MBARD Rule 207 states the following “the requirements to conduct Visibility, Soils and Vegetation Analysis, provide offsets, and conduct an Air Quality Increment Analysis of this Rule shall not apply to any Stationary Source that has emissions less than 10 tons/year of each individual criteria pollutants.”

Rule 207 Parallel Stringency Review

After reviewing the two different versions of Rule 207, the project is in compliance with all the requirements of the Rule as adopted on 4/20/2011 and amended on 2/15/2017.

MBARD Rule 218 – Title V: Federal Operating Permits

Title V is not applicable to the unit since this rule only applies to a stationary source which has the potential to emit (PTE) air contaminants equal to or in excess of the threshold for a major source of regulated air pollutants (100 tons/yr) or a major source of Hazardous Air Pollutants (25 tons/yr combination HAPs or 10 tons/yr single HAP). Table 9 shows facility wide emissions that do not exceed these thresholds.

Table 9 – Facility-wide Annual Emissions

Application No.	NO _x (ton/yr)	VOC (ton/yr)	CO (ton/yr)	SO _x (ton/yr)	PM (ton/yr)	PM ₁₀ (ton/yr)	PM _{2.5} (ton/yr)
MOD-25-00025	0.196	0.006	0.043	0.0003	0.009	0.008	0.008
Total	0.196	0.006	0.043	0.0003	0.009	0.008	0.008

MBARD Rule 221 – Federal Prevention of Significant Deterioration

This project does not meet the definition of a new major stationary source, or a major modification to an existing stationary source. Since the Prevention of Significant Deterioration (PSD) program only applies to new major stationary sources, or major modification to stationary sources, this project is not subject to Rule 221.

MBARD Rule 222 – Minor New Source Review

Compliance with the New Source Review (NSR) provisions of the California Clean Air Act, as defined in MBARD Rule 207, ensures compliance with MBARD Rule 222, Federal Minor NSR.

MBARD Rule 300 – Fees

According to the MBARD Fee Determination Protocol, affirmed and revised by the Board in 2004 and 2023 respectively, fees for an emergency diesel fueled internal combustion engine will be assessed in the fee code category of 202. Table 10 shows the PTE emissions for the diesel fueled internal combustion engine and fee category.

Table 10. PTE For Emergency Diesel Fuel Internal Combustion Engine

Pollutant	Yearly Emissions ¹ (ton/yr)
NO _x	0.196
VOC	0.006
CO	0.043
SO _x	0.0003
PM	0.009
PTE Emissions (tons/yr)	0.254
Fee Category	202

¹ Based on 500 hours per year of max operation for emergency engines, U.S.EPA Memo 9/6/2005.

MBARD Rule 400 – Visible Emissions:

The purpose of this Rule is to provide limits for the visible emissions from sources within MBARD. The provisions of this Rule shall apply to all sources of air pollutant emissions in the MBARD.

According to MBARD Rule 400 Section 3.1, no air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark or darker than Ringelmann 1, or equivalent 20% opacity.

MBARD Rule 402 – Nuisance:

The purpose of this Rule is to provide an explicit prohibition against sources creating public nuisances while operating within the MBARD. The provisions of this Rule shall apply to all sources of air pollutant emissions within the Air MBARD.

According to MBARD Rule 402, Part 3, no person shall discharge from any source whatsoever such quantities of air contaminants or other materials which cause injury, detriment, nuisance, or annoyance to any considerable number of persons or to the public; or which endanger the comfort, repose, health, or safety of any such persons or the public; or which cause, or have a natural tendency to cause, injury or damage to business or property. This requirement will be included as a permit condition.

District Rule 403 – Particulate Matter:

The purpose of this Rule is to provide particulate matter emission limits for sources operating within the

MOD-25-00025	0.196	0.006	0.043	0.0003	0.009	0.008	0.008
Total	0.196	0.006	0.043	0.0003	0.009	0.008	0.008

The General Applicability of this Rule shall apply to any stationary source which would, if it did not comply with the limitations set forth in this rule, have the potential to emit air contaminants equal to or in excess of the threshold for a major source of regulated air pollutants or a major source of hazardous air pollutants (HAPs) and which meets one of the following conditions:

Title V is not applicable because this rule only applies to a stationary source which has the potential to emit air contaminants equal to or in excess of:

- 100 tons/year of criteria pollutants, or
- 25 tons/year of combined hazardous air pollutants combination, or
- 10 tons/year for any single HAP.

Table 11 shows that the annual potential emissions are below the applicability thresholds.

Pursuant to Rule 436 Section 1.2 and 3.1 the facility is exempt from Title V permitting process because it is expected that the actual emissions, will not exceed, in every 12-month period the following:

- 50 tons per year for regulated (criteria) pollutants.
- 5 tons single Hazardous Air Pollutant (HAP) per year
- 12.5 tons per year of any combination of HAPs per year, or
- 50% of any lesser threshold for a single HAP as the EPA may establish.

Table 11 shows that the annual potential emissions are below the applicability thresholds.

Pursuant to Section 1.3.2.1, a facility is exempt from Title V Record keeping requirements of Part 4 if actual emissions do not have the potential to exceed in every 12-month period the following limits:

- 5 tons per year for a regulated (criteria) pollutant
- 2 tons single Hazardous Air Pollutant (HAP) per year
- 5 tons per year of any combination of HAPs per year, or
- 20% of any lesser threshold for a single HAP as the EPA may establish.

Table 11 shows the annual potential emissions are below the applicability thresholds. The facility is entitled to the exemption from record keeping requirements of Rule 436 Part 4.

A facility is entitled to the exemption from Reporting Requirements of Rule 436 Part 5, pursuant to Section 5.2. if actual emissions, based on annual renewal information sheets, will not exceed in every 12-month period the following quantities:

- 25 tons per year including a regulated air pollutant for which the MBARD has a federal area designation of attainment, unclassified transitional, or moderate nonattainment.
- 15 tons per year for regulated (criteria) pollutants for which the MBARD has federal area designation of serious nonattainment.
- 6.25 tons per year for regulated (criteria) pollutants for which the MBARD has federal area designation of severe nonattainment.

- 2.5 tons per year of a single HAP
- 6.25 tons per year of any combination of HAPs
- 25% of any lesser threshold for a single HAP as the U.S. EPA may establish.

As shown in Table 11, the facility is entitled to the exemption from reporting requirements of Rule 436 Part 5.

Rule 1000 – Toxic Air Contaminants:

This Rule applies to any new or modified stationary sources for which an Authority to Construct or a Permit to Operate is required pursuant to MBARD Regulation II - Permits, and which has the potential to emit into the atmosphere any TAC (Toxic Air Contaminant). Whenever a potential TAC may be subject to more than one MBARD Rule, or to more than one requirement in this rule, the requirement resulting in the least hazard to the public, as determined by the Air Pollution Control Officer, shall apply.

MBARD Rule 1000 Part 3 requires new or modified sources of toxic air contaminants (TAC) and carcinogenic toxic air contaminants (CATC) to meet the following:

- 3.1.1 The acute hazard index for any target organ or organ system due to TAC emissions from the new or modified permit unit shall not exceed 1.0 at any receptor location;
- 3.1.2 The chronic hazard index for any target organ or organ system due to TAC emissions from the new or modified permit unit shall not exceed 1.0 at any receptor location;
- 3.1.3 The cancer risk due to TAC emissions from the new or modified permit unit shall not exceed 10 in one million at any receptor location.

Combustion of diesel fuel results in the emissions of toxic air contaminants (TAC). However, pursuant to Section 1.3 of this Rule, the provisions of this Rule shall not apply to any Source Category that has an existing State Air Toxics Control Measure (ATCM). Since the diesel-powered engine generator set is subject to the ATCM for Stationary Compression Ignition Engines, the project is exempt from Rule 1000.

Air Toxic “Hot Spots” Information and Assessment Act

Due to the toxicity nature of diesel PM, the emergency diesel engine is subject to the requirements of AB2588, Air Toxic “Hot Spots” Information and Assessment Act of 1987. Section 3.1 allows the use of the current California Air Pollution Control Officers Association Prioritization Guidelines in lieu of a risk assessment. Thus, a prioritization assessment was conducted for informational purposes, using 50 hours per year of operations, not actual annual hours of operation. The nearest receptor is located 82.2 meters away from the source. As shown in Table 12, the emergency diesel engine prioritization score for acute risk is less than 1, chronic & cancer health risks are greater than 1 and less than 10. Therefore, for AB2588 purposes, the engine will be categorized as Intermediate priority.

Table 12. Prioritization Scores

Risk Category	Prioritization Score (PS)	Corresponding PS Threshold	AB2588 Facility Designation
Acute Risk	0.00E+00	≤ 1	Low Priority
Chronic Risk	1.04E+00	1 < PS < 10	Intermediate Priority
Cancer Risk	4.00E+00	1 < PS < 10	Intermediate Priority

Rule 1010 – Air Toxic Control Measure for Stationary Compression Ignition Engines:

The purpose of this rule is to reduce diesel particulate matter (PM) from stationary diesel-fueled compression ignition (CI) engines and consistent with California Health and Safety Code Section 39666(d) is a replacement rule for 17 California Code of Regulations Section 93115, Airborne Toxic Control Measure for Stationary Compression Ignition Engines.

Except as provided in Section 1.3, this Rule applies to any person who sells a stationary CI engine, offers a stationary CI engine for sale, leases a stationary CI engine, or purchases a stationary CI engine for use, unless such engine is: a portable CI engine, a CI engine used to provide motive power, an auxiliary CI engine used on a marine vessel, or an agricultural wind machine. Per section 1.2.2 the Rule applies to any person who owns or operates a stationary CI engine in the MBARD with a rated brake horsepower greater than 50 (>50 bhp).

Fuel and Fuel Additive Requirements

Pursuant to Section 3.1, no owner or operator of any stationary diesel-fueled CI engine shall add to the engine, or any fuel tank directly attached to the engine any fuel unless the fuel is one of the following:

- CARB Diesel Fuel; or
- An alternative diesel fuel that is:
 - biodiesel;
 - a biodiesel blend that does not meet the definition of CARB Diesel Fuel.
 - a Fischer-Tropsch fuel; or
 - an emulsion of water in diesel fuel; or
- Any alternative diesel fuel that is not identified in Subsection 3.1.2 above and meets the requirements of the Verification Procedure; or
- An alternative fuel; or
- CARB Diesel Fuel used with fuel additives that meets the requirements of the Verification Procedure; or
- Any combination of the above fuels.

Emergency Standby Diesel-Fueled CI Engines (>50 HP) – Diesel PM Standard

Pursuant to Section 3.2.1.3.1, the emissions from the new stationary emergency standby diesel-fueled engine shall be less than or equal to 0.15 g/bhp-hr; or meet the diesel PM standard, as specified in the Federal Standards of Performance for Stationary Compression Ignition Internal Combustion Engines with the same maximum rated power (40 CFR Part 60, Subpart IIII), in effect on the date of acquisition or submittal, as defined in Section 2.15 whichever is more stringent. The installed engine is a Tier 3 unit and meets the requirements of this Section.

New Emergency Standby Diesel Engine At-School and Near-School Provisions

Pursuant to Section 3.2.1.1, no owner or operator shall operate a new stationary emergency diesel engine for non-emergency use (including maintenance and testing) with emissions of greater than 0.01 g/bph-hr of diesel PM during the following periods:

- Whenever there is a school sponsored activity, if the engine is located **on school grounds**, and

- Between 7:30 a.m. and 3:30 p.m. on days when school is in session, if the engine is located **within 500 feet of school grounds**.

The unit is not located within 500 feet of the Greenfield high school grounds. Hence, the facility is not subject to this requirement.

Emergency Standby Diesel-Fueled CI Engines (>50 HP) – Maintenance & Testing: Hours of Operation

Pursuant to Section 3.2.1.3.1.1.3, the new engines shall not operate more than 50 hours per year for maintenance and testing purposes. This subsection does not limit operation for emergency use and for emission testing to show compliance with Subsection 3.2.1.3. A permit condition will be added to meet this requirement.

Record-keeping Requirements

MBARD Rule 1010 Section 4.1.5 requires a non-resettable hour meter to be installed with a minimum display capacity of 9,999 hours. Furthermore, MBARD Rule 1010 Section 4.1.7 requires the monthly reporting of the following:

- Emergency use hours of operation;
- Maintenance and testing hours of operation;
- Hours of operation for emission testing to show compliance with Section 3.2.1
- Initial start-up testing hours; and,
- Fuel used.

Lastly, pursuant to MBARD Rule 1010 Section 4.1.7.2, the owner or operator of the diesel engine must retain records for a minimum of 36 months and maintain on-site records for the prior 24 months. Records from the prior 25 to 36 months must be made available to MBARD staff within 5 working days from the request date.

40 CFR Part 63, Subpart ZZZZ, NESHAP, National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

Subpart ZZZZ establishes national emission limitations and operating limitations for hazardous air pollutants (HAP) emitted from stationary reciprocating internal combustion engines (RICE) located at major and area sources of HAP emissions. An area source of HAP is defined as a plant site that emits or has the potential to emit any single HAP at a rate of less than 10 tons per year or any combination of HAPs at a rate of less than 25 tons per year. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations and operating limitations.

Pursuant to Section §63.6590(a)(2)(iii), an affected source includes new stationary RICEs located at an area source of HAP emissions. This unit is considered a new stationary RICE at an area source of HAP since construction commenced after June 12, 2006.

As an affected source, pursuant to §63.6590(c) & §63.6590(c)(1), any new or reconstructed stationary Rice located at an area source must meet the requirements of this part by meeting the requirements of 40 CFR Part 60 Subpart IIII, NSPS for compression ignition engines and no further requirements apply for such engines under this part. Therefore, the facility will comply with NESHAP ZZZZ by complying with NSPS

III, as outlined in the next section below.

40 CFR Part 60, Subpart III, NSPS, Standards of Performance for Stationary Compression Ignition Internal Combustion Engines

Per Section §60.4200 (a)(2) & 60.4200 (a)(3), Subpart III applies to owners and operators of stationary CI ICE that commenced construction after July 11, 2005, and manufactured after April 1, 2006, and are not fire pumps. Per Section §60.4205(b), owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new nonroad CI engines in §60.4202.

For engines with a rated power greater than or equal to 37 KW (50 HP), the Tier 3 emission standards for new nonroad CI engines for the same rated power as described in 40 CFR part 1039, appendix I, for all pollutants and the smoke standards as specified in 40 CFR 1039.105 beginning in model year 2006.

The engine is rated at 80 kW, meets Tier 3 emission standards and complies with the requirements of 40 CFR Part 60, Subpart III. Table 13 shows the comparison of Table 3 of Appendix I to Part 1039(c) standards and the installed engine emissions from manufacturer specifications.

Table 13. Standards for Engines Rated $75 \leq \text{kW} < 130$ for Tier 3, starting model year 2007.

Pollutant	Emission Standards (g/kW-hr)	Installed Engine Emissions (g/kW-hr)	Compliance
NMHC + NO _x	4.00	3.76	Yes
CO	5.00	0.80	Yes
PM	0.30	0.16	Yes

As shown in Table 13, the emergency diesel engine meets the emissions requirement of this section.

Compliance Requirements

Section §60.4211(a) requires operating and maintaining the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions and only changing those emission-related settings that the manufacturer permits; and to meet the requirements of 40 CFR part 1068, as applied to the engine subject to the evaluation.

Section §60.4211(c) requires the engine must be installed and configured according to the manufacturer's emission-related specifications. **The owner has agreed to install, configure and operate the unit in compliance with §60.4211(a) and (c).** Compliance requirements will be included as a permit condition.

Pursuant to Section §60.4211(g), if the owner or operator does not install, configure, operate, and maintain the engine and control device according to the manufacturer's emission related written instructions, or changes emission-related settings in a way that is not permitted by the manufacturer, the legal owner or operator must demonstrate compliance according to the provisions of §60.4211(g)(2) as the engine is rated as 131 HP.

NOTE: Such an action described above would constitute a permit modification per the requirements of MBARD Rule 207 - Sections 1.2 & 2.33.1, Rule 1000 - Sections 1.2 & 2.9 and would require a demonstration of compliance with Rule 1010 - Section 3.3. Hence, the requirements and allowances of

Section §60.4211(g) cannot be incorporated into the permit at this time.

For informational purposes only, should the facility submit an application for a permit modification to reevaluate the project for the change in method of operation, revisions to the potential to emit, and compliance with Rules 1000 & 1010, and MBARD is able to make the appropriate findings, an ATC could be issued with the following requirements of §60.4211(g) for the respective sized engine listed below:

For engines greater than or equal to 100 HP and less than or equal to 500 HP,

- must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable,
- maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition,
- must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine and control device is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after you change emission-related settings in a way that is not permitted by the manufacturer.

Should §60.4211(g) need to be taken into consideration at a future date, the initial performance would be required within 180 days (6 months), to align with MBARD's Source Testing Protocol.

Compliance requirements will be included as a permit condition.

Fuel Requirements

Per Section §60.4207, beginning October 1, 2010, owners and operators of stationary CI ICE subject to subpart III, with a displacement of less than 30 liters per cylinder that use diesel fuel, must use diesel fuel that meets the requirements of 40 CFR 1090.305 except as specified in Section §1090.3009 (a). Requirements: the maximum sulfur content of 15 ppm and must meet one of the following standards a minimum cetane index of 40 or maximum aromatic content of 35% by volume.

The use of diesel that meets California Air Resources Board (CARB) specification, or the alternative diesel fuel specifications as defined in MBARD Rule 1010 will comply with the fuel requirements of this section.

Monitoring Requirements §60.4209 (a) & (b)

If you are an owner or operator of an emergency stationary CI internal combustion engine that does not meet the standards applicable to non-emergency engines, you must install a non-resettable hour meter prior to startup of the engine. Since this engine does not meet Tier 4 standards, the unit must be equipped with a non-resettable hour meter. The requirement to install a non-resettable hour meter is also required by MBARD Rule 1010.

If you are an owner or operator of a stationary CI internal combustion engine equipped with a diesel particulate filter to comply with the emission standards in §60.4204, the diesel particulate filter must be installed with a backpressure monitor that notifies the owner or operator when the high backpressure limit of the engine is approached. The engine is not equipped with a DPF and hence not subject to part (b).

Recordkeeping Requirements

Per Table 5 to subpart III, starting model year 2012, an engine rated $56 \leq \text{KW} < 130$ ($75 \leq \text{HP} < 175$) must comply with the requirements of Section §60.4214(b) as follows:

If the emergency engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.

Recordkeeping requirements will be included as a permit condition.

Health & Safety Code (H&SC) Section 42301.6 – Public Notification Requirements:

Pursuant to Section §42301.6(a), prior to approving an application for a permit to construct or modify a source that emits hazardous air emissions, and that source is located within 1,000 feet from the outer boundary of a school site, the air pollution control officer shall prepare a public notice in which the proposed project or modification for which the application for a permit is made is fully described.

The notice may be prepared whether or not the material is or would be subject to subdivision (a) of Section 25536, if the air pollution control officer determines and the administering agency concurs that hazardous air emissions of the material may result from an air release, as defined by Section 44303. The notice may be combined with any other notice on the project or permit that is required by law.

The district protocol adopted by the board on 11/14/01 specifies the risk thresholds for public notification. If the carcinogenic risk is in excess of 1 in a million, or non-carcinogenic risk is at or above the applicable reference exposure levels, the district will conduct a public notice.

The engine is subject to this evaluation, as it is located within 1,000 feet of the outer boundary of a K through 12-grade school.

The district protocol adopted by the board on 11/14/01 specifies the risk thresholds for public notification. If the carcinogenic risk is in excess of 1 in a million, or non-carcinogenic risk is at or above the applicable reference exposure levels, the district will conduct public notice.

This engine is subject to this evaluation, as it is located within 1,000 feet of the Greenfield High School and therefore, the project is subject to the public notification requirements.

Lakes Environmental AERMOD was used to model the concentrations from the emergency diesel engine generator. The AERMOD concentration files were used in CARB’s Air Dispersion Modelling Risk Tool (ADMRT).

Table 14 shows the parameters used to model the emergency diesel engine.

Table 14 – Engine rated 131 HP modelling parameters.

Source ID ¹	1
Source type ²	Point
X Coordinate	658106.00

Y Coordinate	4020410.00
Base elevation ³ (ft)	269.03 ft
Release height (ft)	5.75
Emissions rate ⁴	1 g/s
Stack diameter (ft)	0.25
Gas exit flow rate	790 cfm
Gas exit temperature	887 ° F
Met station elevation ⁵ (m)	50.3
Maximum 1-hr Concentration	2235.24 µg/m ³
Maximum Period Concentration	71.96 µg/m ³

- 1 Source ID 1 is used because AERMOD results will be loaded into CARB’s ADMRT tool where source ID will be identified as 1.
 2 Since the engine is equipped with a vertical exhaust, a point source was selected.
 3 Base elevation was uploaded automatically when running AERMAP on AERMOD.
 4 Emission rate set to 1 g/sec because AERMOD results will be loaded into CARB’s ADMRT tool.
 5 Met elevation from CARB’s HARP AERMOD Meteorological Files web page: [HARP AERMOD Meteorological Files | California Air Resources Board.](#)

The following options were selected when running the HARP2 risk assessment:

- Analysis type: cancer, chronic, and acute.
- Receptor type: individual resident
- Exposure duration: 30 years
- Intake rate percentile: OEHHA derived method
- Pathways to evaluate mandatory minimum pathways.

Table 15 shows the Health Risk Assessment (HRA) values of the proposed project for surrounding exposure.

Per MBARD’s protocol on Public Notification Requirements (Health & Safety Code 42301.6), adopted by the Board On 11-14-01, the Public Notification Requirements of H&SC 42301.6 are not required for any project if:

- Carcinogenic Risk is less than 1 in a million.
- Non-Carcinogenic risks are less than the applicable Reference Exposure Levels (RELs).

The acute and chronic risks are below the RELs & MBARD’s Rule 1000 threshold of 1.0. However, the cancer risks exceed an excess risk of 1 in a million. Hence, according to MBARD Protocol, this engine requires public notice.

Table 15. Health Risk Assessment Results For School Receptor

Risk	Receptor ID	x-coordinate	y-coordinate	Value	Rule 1000 compliant?	Trigger Health and Safety Code & Public Notice ¹
Acute Max HI	1	593187	4048447	0.0000e+00	Yes	No
Chronic Max HI	883	658131	4020435	3.5814e-04	Yes	No
Cancer	883	658131	4020435	1.5493e-06	Yes	Yes

Risk						
------	--	--	--	--	--	--

1. Reference: MBARD Protocol, Public Notification Requirements - H&SC 42301.6, Affirmed By The Board On 11-14-01

VI. CONCLUSIONS

The equipment has the capability to continue to comply with all applicable MBARD rules and regulations.

VII. RECOMMENDATIONS

Upon completion of the public notification process, issue Authority to Construct with the following additional conditions:

1. No later than twenty-four (24) hours prior to start-up of the equipment, City of Greenfield shall notify Monterey Bay Air Resources District (MBARD) and arrange for an inspection of the equipment during normal operations to verify compliance with MBARD rules and regulations. [Basis: MBARD Rule 207]
2. Annual engine diesel fuel usage, emergency use hours of operation, and maintenance and testing hours of operation shall be reported to MBARD, upon request. [Basis: MBARD Rule 207]
3. Except for maintenance and testing purposes, this equipment shall only be operated when the local utility powerline service fails. [Basis: MBARD Rule 1010]
4. The equipment shall be operated less than 50 hours per year for maintenance and testing purposes. [Basis: MBARD Rule 1010]
5. City of Greenfield shall maintain a log, summarized monthly, to record the following:
 - a. Date of operation;
 - b. Start and end engine hour meter readings;
 - c. Emergency use hours of operation;
 - d. Maintenance and testing hours of operation; and,
 - e. Fuel usage, (gallons/month). If no fuel records are available, reported fuel usage can be based on a maximum fuel usage rate of 6.84 gallons per hour for this engine.

Records shall be retained for at least three years and made readily available to MBARD staff upon request. [Basis: MBARD Rule 1010 & 40 CFR 60, Subpart III § 60.4214(b)]

6. The engine shall be equipped with a non-resettable meter which registers the total hours operated and shall be maintained in good working condition. [Basis: MBARD Rule 1010 & 40 CFR 60, Subpart III § 60.4214(a)]
7. The engine must be installed and configured according to the manufacturer's emission-related written instructions. [Basis: 40 CFR 60, Subpart III §60.4211(c)]
8. The engine shall be operated and maintained in accordance with manufacturer's emission-related written instructions. Maintenance records shall be retained with other required engine operational data as

specified in Condition 5. [Basis: MBARD Rules 207 and 1010 & 40 CFR 60, Subpart III §60.4211(a)]

9. Operation of the engine, that is not in accordance with the manufacturer's emission-related written instructions, or changes in the manufacturer's emission-related settings constitutes a modification of the permit and requires prior MBARD approval. [Basis: MBARD Rule 207 & 40 CFR 60, Subpart III §60.4211(g)]
10. The diesel fuel consumed shall meet California Air Resources Board (CARB) specifications, or the alternative diesel fuel specifications as defined in MBARD Rule 1010. [Basis: MBARD Rule 1010]
11. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, an interruptible power contract, or base interruptible program. [Basis: MBARD Rule 1010]
12. The exhaust stack discharge shall be vertically configured and equipped without a stationary cap. [MBARD Rule 402]
13. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark or darker than Ringelmann 1, or equivalent 20 percent opacity. [Basis: MBARD Rule 400]
14. No emissions shall constitute a public nuisance. [Basis: MBARD Rule 402]