



MONTEREY BAY AIR RESOURCES DISTRICT

24580 Silver Cloud Court, Monterey, CA 93940

(831) 647-9411, www.mbard.org

DROP TUBE/DRAIN VALVE PRESSURE INTEGRITY TEST

TP 201.1C

TP 201.1D

Annual Testing

Engineering Startup Evaluation

SOURCE INFORMATION				TEST COMPANY INFORMATION			
Facility (DBA)/Site Address:		Facility Representative/Title:		Company Name/Address		Company Representative	
Print Name		Print Name		Print Name		Print Name	
Print DBA (if applicable)		Title		Street Address		Signature	
Street Address		Phase I System: Executive Order #:		City	Zip	Phone No.	
City	Zip	Phone No.		Date of Test		ICC Cert. No.	
District Test Witness:		<input type="checkbox"/> P/O <input type="checkbox"/> A/C Number:					

Drop Tube Overfill Protection Device Installed? Yes No

Ball Float Vent Valve Installed? Yes No

UST INFORMATION: (only required for TP 201.1D)

Product	Drop Tube (SFP) Measurement	Height of Product	Is Product >4" above bottom of Drop Tube (SFP)? (If no, do not conduct test) Check Yes or No
			<input type="checkbox"/> Yes <input type="checkbox"/> No
			<input type="checkbox"/> Yes <input type="checkbox"/> No
			<input type="checkbox"/> Yes <input type="checkbox"/> No
			<input type="checkbox"/> Yes <input type="checkbox"/> No

TEST DATA:

Pressure measuring device calibration date: _____

Flow meter calibration date: _____

Product Grade	Product Adaptor Make/Model	Time (seconds) to reach 2.00 "w.c at 0.17 CFH	30-second stabilizing flow rate (CFH) at 1.95" – 2.05"	TP 201.1D only Time (seconds) to reach 2.00 "w.c at 0.42 CFH	TP 201.1D only 30-second stabilizing flow rate (CFH) at 1.95" – 2.05"	PASS /FAIL