



**MONTEREY BAY AIR RESOURCES DISTRICT**

24580 Silver Cloud Court, Monterey, CA 93940

(831) 647-9411, [www.mbard.org](http://www.mbard.org)

**Ten Gallon per Minute Limitation Test Report Form**

**ARB Executive Order G-70-187 Exhibit 6**

Permit Number:		Test Company:	
Site Name:		Technician:	
Site Address:		Certification Number	Expiration Date
City:	Zip:	District:	
Date/Time of Test:		ICC:	

Nozzle #	1	2	3	4	5
Time elapsed @ 2.0 gallons dispensed					
# gallons ÷ # of seconds × 60 = gallons per minute					
Time elapsed @ 3.0 gallons dispensed					
# gallons ÷ # of seconds × 60 = gallons per minute					
Time elapsed @ 4.0 gallons dispensed					
# gallons ÷ # of seconds × 60 = gallons per minute					
Time elapsed @ 5.0 gallons dispensed					
# gallons ÷ # of seconds × 60 = gallons per minute					
Pass / Fail <sup>1</sup>					

<sup>1</sup>The maximum gallons per minute allowed is 10.0.